

Sewer Discharges into Bryan County’s system shall conform with the latest revisions of *Sec. 30-114 – General Sewer Use Requirements* of the Bryan County Code of Ordinances. The following is an excerpt from this section that presents pollutant limits, which have been established to protect against interference with the County’s sewer collection and treatment systems. Discharge limits must also conform to the *Bryan County-City of Savannah Sewer Service Agreement*, which prohibits toxic materials which would interfere with Savannah’s or Bryan County’s biological treatment processes, and shall not exceed the more stringent of either Bryan’s or Savannah’s current industrial pretreatment requirements.

No person or entity shall discharge wastewater containing in excess of the following instantaneous maximum allowable discharge limits (mg/L):

**Maximum Concentration**

<u>Constituent</u>	<u>Mg/L</u>
BOD	300
COD	500
pH	6 – 9.5
Fat, Oil, and Grease	100
TOC	200
Total Suspended Solids	280
Arsenic	0.077
Cadmium	0.004
Chromium	0.57
Copper	0.63
Cyanide	0.30
Lead	0.05
Mercury	0.014
Molybdenum	0.043
Nickel	0.61
Total PAH	0.100
Benzene	0.01
Toluene	0.7
Residual chlorine	4.00
Total phenols	21
Selenium	0.17
Silver	0.5
Surfactants	100
Total toxic organics	2.13
Zinc	0.88
Ammonia	55
Phosphorus	12
Elthylbenzene	0.3
Total xylene	0.5
Chloride	250
Sulfate	500